

MODEL: BL610-CF  
COOLER 35°

**Arctic**<sup>®</sup>  
WALK-IN COOLERS AND FREEZERS  
BY ARCTIC INDUSTRIES, INC.  
9731 N.E. 114th BLDG. 1846 FLORIDA 33178  
PHONE: (305) 983-9881

GENERAL NOTE  
NOTICE TO GENERAL CONTRACTOR AND SUB-CONTRACTOR. UNIT QUARRY TILE OR CONCRETE WEARING FLOORS, THE METAL FININGS MAY BE SUSCEPTIBLE TO STAINING DUE TO EXCESSIVE MOISTURE CREATED BY HYDRATION OF CONCRETE-TYPE MATERIALS. IT IS ESSENTIAL THAT EACH ROOM BE PROPERLY VENTILATED. SPECIAL PRECAUTIONS MUST BE TAKEN WHEN USING MURIATIC ACID DUE TO EFFECTS OF ACID FUMES ON ALUMINUM AND STAINLESS STEEL. IN ADDITION, METAL SURFACES MUST BE PROTECTED FROM LIME AND OTHER CHEMICALS FOUND IN CONCRETE BY-PRODUCTS. PETROLEUM BASED PROTECTION MUST BE APPLIED BETWEEN CONCRETE AND THE METAL SURFACES. (LIQUID TAR, BRUSHED OR SPRAYED ABOVE THE CONCRETE CONTACT LINE, HEAVY EPOXY PAINT, 8 MIL POLYETHYLENE H.D. BLACK DOUBLE LAYERED, 30 LB. ASPHALT IMPREGNATED ROOFING PAPER).

**CONSTRUCTION**

N.S.F. CONSTRUCTION  
Project Name:  
ARCTIC INDUSTRIES, INC  
BLUE LINE

P.O.#:  
APPLICATION:  
MODEL: BL610-CF

NOTES:  
FLOOR MUST BE LEVEL SMOOTH AND CLEAR OF OBSTRUCTIONS TO ACCEPT WALK-IN PANELS. ALSO, THERE MUST BE A MINIMUM OF 2" CLEARANCE AROUND ALL SIDES OF THE WALK-IN UNIT PROPER CIRCULATION.  
VERIFY ALL DIMENSIONS AND SPECIFICATIONS BE UNITE APPROVING DRAWINGS

IMPORTANT: ALLOW 2 FEET CLEARANCE ABOVE UNIT TO REMOVE TOP PANEL AND TO ALLOW SERVICE ACCESS.

STRUCTURE MUST BE NOT MASKED TO BUILDING CEILING, BLOCKING AIR FLOW TO UNIT.

SIGNED APPROVED PRINT MUST BE REC'D. B/4 FAB.

APPROVED AS DRAWN


SIGNED \_\_\_\_\_

DATE: \_\_\_\_\_



Drawn By: R.PUPO  
Checked By: ARCTIC  
Scale: NOT TO SCALE  
CREATED: 2014

DRW No: \_\_\_\_\_


BL610-CF



PLAN VIEW




REFRIGERATION UNIT



ELEVATION

SHOWN W/ RIGHT HINGE  
(LEFT HINGE AVAILABLE)



WALLS & TOP MOUNT  
S/C SECTION

PRODUCT SPECIFICATIONS	
MODEL:	BL610-CF
INTERIOR/EXTERIOR FINISH	MILL EMB. ACRYLUME
COMPT ELECTRICAL (VOLTS/Hz/PH)	115/60/1
COMPT AMP.	0.8 Amp
REFRIG. SYSTEM ELECT (VOLTS/Hz/PH)	208-230/60/1
REFRIG. SYSTEM AMP.	12.0 Amp
CORD + NEMA 6-20P PLUG	
REFRIG. SYSTEM WEIGHT.	220 Lbs
TOTAL SHIP WGT APPROX. (2 PALLETS)	830 Lbs
TOTAL SHIP CUBIC FEET APPROX.	201 CuFt