

	;	8	7	6	5 4 3
D	ITEM NO.	QTY.	PART NO. / DWG. NO.	MATERIAL	DESCRIPTION
	1	1	D-1111	STAINLESS STEEL	BACK CASING ASSEMBLY
	2	1	D-1110	STAINLESS STEEL	FRONT COVER
	3	1	JTK6-FM	COPPER / BRASS	HEATER TUBE ASSEMBLY
	4				
	5	6	N1375-8000	INCOLOY / BRASS	HEATING ELEMENT, 8000W @ 240V
	6	1	D-1114	ALUMINUM	TOP HEATER TUBE SUPPORT
	7	6	20603L13-44	VARIOUS	HI-LIMIT SWITCH, AUTO RESET (SET TO 200°F)
	8	1	TK FLOW BR	BRASS	FLOW METER, 0.2-8 GPM
	9				
	10	1	TK2250	VARIOUS	ELECTRONIC TEMPERATURE CONTROLLER
	11	1	TKD2000	VARIOUS	LED DISPLAY
	12	6	TG40E60	VARIOUS	TRIAC
	13	2	USP9509	VARIOUS	THERMISTOR
	14	AS REQ'D		COPPER	WIRE: POWER: #8 AWG, CONTROL: #18 AWG, THHN (90°C)
	15	1	KA-4C	COPPER	GROUND LUG
	16	1		POLYURETHANE	THERMISTOR INSULATION
	17	2	67572	VARIOUS	POWER DISTRIBUTION BLOCK
	18				
С	19				
	20	3	PLUGBR 1/8	BRASS	DRAIN PLUG, 1/8" NPT
	21	5		RUBBER	INLET / OUTLET / DRAIN CASING GASKETS
	22	1	TANKLESS OVERLAY	LEXAN	DISPLAY OVERLAY
	23	1	COUPBELL 1/2" TO 3/4"	BRASS	INLET BELL COUPLING, 1/2" x 3/4"
	24	1	DIELECTRIC UNION	VARIOUS	DIELECTRIC UNION, 3/4" FNPT x 3/4" CTS
	25				
-	26	1		STAINLESS STEEL	INLET SCREEN (NOT SHOWN)
	27				
	28				
B	29	1		VARIOUS	LEAK DETECTION WIRE
	30	AS REQ'D		RUBBER	GASKET MATERIAL (NOT SHOWN)
	31	1	NIPPBR 3/4 X 1.5	BRASS	NIPPLE 3/4" x 1 1/2" LONG
	32	1	LGR-3	VARIOUS	CONTROL CIRCUIT FUSE, 3A
	33	1	LHR000	VARIOUS	FUSE HOLDER
			1	1	

INSTALLATION PARAMETERS						
VOLTS	240 V					
POWER	48 kW					
 AMP	200.0 A					
BREAKER SIZE(MIN)	225 A					
FEED WIRE SIZE(MIN)	4/0 AWG					
CONDUIT SIZE(MIN)	2"					
WIRING DIAGRAM	6					

INSTALLATION NOTES:

1. TANKLESS WATER HEATERS ARE CONSIDERED A NON-CONTINUOUS LOAD.

5

- IF MULTIPLE FEED INSTALLATION IS USED, IT IS ACCEPTABLE TO INSTALL UP TO TWO 2. CONDUCTORS IN ONE LINE SIDE PORT. ADDITIONALLY, WHEN A POWER DISTRIBUTION BLOCK IS SUPPLIED, ADDITIONAL CONDUCTORS MAY BE INSTALLED IN AN OPEN LOAD SIDE PORT OF THE POWER DISTRIBUTION BLOCK.
- WIRING SIZING LISTED IS FOR 75°C THHN. 60°C OR 90°C WIRE MAY BE USED. REFER TO 3. NEC TABLE 310.16 FOR SIZING.
- 4. CONDUCTORS SHOULD BE SIZED TO MAINTAIN A VOLTAGE DROP OF LESS THAN 3% UNDER LOAD.
- DRAWN 5. THESE MODELS INDICATED REQUIRE THAT A SUPPLEMENTARY PROTECTION ASSEMBLY CHECKED BE INSTALLED (SUPPLIED BY HUBBELL). IF SUPLLEMENTAL PROTECTION IS SUPPLIED BY ENG APPR. OTHERS, WHERE MULTIPLE FEEDER CONNECTIONS ARE USED, PHASES MUST BE FROM MFG APPR. THE SAME SOURCE.

PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF THE ELECTRIC HEATER COMPANY. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF THE ELECTRIC HEATER COMPANY IS PROHIBITED.	Dimen Toler (Unles Fract Angu Two F Three

ENSIC RAN ESS C CTION ULAF PLA e pla

1.

А

8

7

6

4

3

I		2			I		1		
									D
W/ 2. UN 3. JTX 4. AP 5. HE/ FRO	ATING Ater P It Is UI Flov Prox Aters OM 0	TES: CHAI RESSU L, CUL, V RATE IMATE ARE F TO 100 ESIGN	RE (N ANE :: 0.2 WEIC ULLY)%.	/IAX.) D UL E GPM GHT IS MOE	PH LIS MIN., 5 18 PC DULATI	ted. 8 gpi Dund: Ng	M MA	Χ.	С
									-
									В
ZONE F	REV.		DES		10		DATE	APPROVED	-
	DATE	NAME		REVISION			Stratford,	CT 06615	
RAWN	11/17/10	PRD			hel		203) 378-	2659	
HECKED	11/22/10	SW	Τ	he El	ectric	Heate	r Con	npany	4.
NG APPR.	11/22/10	PRD	Custor						A
IFG APPR. 11/22/10 WEN III DIMENSIONS ARE IN INCHES TOLERANCES: (UNLESS OTHERWISE SPECIFIED) FRACTIONAL ±¼ ANGULAR: MACH ±½° BEND ±1°			TANK	LESS EL V @ 240 DWG	.ectric) V, 1Ph . NO.)48-6S	BOOSTE	R HEATE	er, Rev	-
TWO PLACE D THREE PLACE [SCAL	E: 1:1	FSCM:	19857	SHEE	T 2 OF 2	1
		2			1		1		L