

| _ | |) | , | O . | 3 4 3 |
|---|----------|----------|-----------------------|-----------------|---|
| D | ITEM NO. | QTY. | PART NO. / DWG. NO. | MATERIAL | DESCRIPTION |
| | 1 | 1 | D-1111 | STAINLESS STEEL | BACK CASING ASSEMBLY |
| | 2 | 1 | D-1110 | STAINLESS STEEL | FRONT COVER |
| | 3 | 1 | JTK6-FM | COPPER / BRASS | HEATER TUBE ASSEMBLY |
| | 4 | | | | |
| | 5 | 6 | N1375-8000 | | HEATING ELEMENT, 8000W @ 240V |
| | 6 | 1 | D-1114 | ALUMINUM | TOP HEATER TUBE SUPPORT |
| | 7 | 6 | L93 | VARIOUS | HI-LIMIT SWITCH, AUTO RESET (SET TO 200°F) |
| | 8 | 1 | TK FLOW BR | BRASS | FLOW METER, 0.2-8 GPM |
| | 9 | | | | |
| | 10 | 1 | TK2250 | VARIOUS | ELECTRONIC TEMPERATURE CONTROLLER |
| | 11 | 1 | TKD2000 | VARIOUS | LED DISPLAY |
| | 12 | 6 | TG40E60 | VARIOUS | TRIAC |
| С | 13 | 2 | USP9509 | VARIOUS | THERMISTOR |
| | 14 | AS REQ'D | | COPPER | WIRE: POWER: #10 AWG, CONTROL: #18 AWG, THHN (90°C) |
| | 15 | 1 | KA-4C | COPPER | GROUND LUG |
| | 16 | 1 | | POLYURETHANE | THERMISTOR INSULATION |
| | 17 | | | | |
| | 18 | 2 | C25DNF350B | VARIOUS | MAGNETIC CONTACTOR, 208/240 VAC COIL, 65A RESISTIVE |
| | 19 | | | | |
| | 20 | 3 | PLUGBR 1/8 | BRASS | DRAIN PLUG, 1/8" NPT |
| | 21 | 5 | | RUBBER | INLET / OUTLET / DRAIN CASING GASKETS |
| | 22 | 1 | TANKLESS OVERLAY | LEXAN | DISPLAY OVERLAY |
| | 23 | 1 | COUPBELL 1/2" TO 3/4" | BRASS | INLET BELL COUPLING, 1/2" x 3/4" |
| | 24 | 1 | DIELECTRIC UNION | VARIOUS | DIELECTRIC UNION, 3/4" FNPT x 3/4" CTS |
| | 25 | | | | |
| - | 26 | 1 | | STAINLESS STEEL | INLET SCREEN (NOT SHOWN) |
| | 27 | 1 | 16023-3 | VARIOUS | POWER DISTRIBUTION BLOCK |
| | 28 | | | | |
| В | 29 | 1 | | VARIOUS | LEAK DETECTION WIRE |
| | 30 | AS REQ'D | | RUBBER | GASKET MATERIAL (NOT SHOWN) |
| | 31 | 1 | NIPPBR 3/4 X 1.5 | BRASS | NIPPLE 3/4" x 1 1/2" LONG |
| | 32 | 1 | LGR-3 | VARIOUS | CONTROL CIRCUIT FUSE, 3A |
| | 33 | 1 | LHR000 | VARIOUS | FUSE HOLDER |
| ۲ | | | | | |

INSTALLATION NOTES: TANKLESS WATER HEATERS ARE CONSIDERED A NON-CONTINUOUS LOAD.

IF MULTIPLE FEED INSTALLATION IS USED, IT IS ACCEPTABLE TO INSTALL UP TO TWO CONDUCTORS IN ONE LINE SIDE PORT. ADDITIONALLY, WHEN A POWER DISTRIBUTION BLOCK IS SUPPLIED, ADDITIONAL CONDUCTORS MAY BE INSTALLED IN AN OPEN LOAD SIDE PORT OF THE POWER DISTRIBUTION BLOCK.

WIRING SIZING LISTED IS FOR 75°C THHN. 60°C OR 90°C WIRE MAY BE USED. REFER TO NEC TABLE 310.16 FOR SIZING.

CONDUCTORS SHOULD BE SIZED TO MAINTAIN A VOLTAGE DROP OF LESS THAN 3% 4. UNDER LOAD.

GENERAL NOTES:

- HEATING CHAMBER IS RATED FOR 150 PSI WATER PRESSURE (MAX.)
- UNIT IS UL, CUL, AND UL ÉPH LISTED.
 - JTX FLOW RATE: 0.2 GPM MIN., 8 GPM MAX.
- APPROXIMATE WEIGHT IS 18 POUNDS.
- HEATERS ARE FULLY MODULATING FROM 0 TO 100%.
- UNIT IS DESIGNED FOR 50/60 Hz.

DATE APPROVED ZONE REV. DESCRIPTION REVISIONS DATE NAME (203) 378-2659 PRD 11/17/10 The Electric Heater Company SW 11/22/10 PRD Customer: ENG APPR. 11/22/10 11/22/10 WEN III Description: MFG APPR. TANKLESS ELECTRIC BOOSTER HEATER,

PROPRIETARY AND CONFIDENTIAL

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF THE ELECTRIC HEATER COMPANY. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF THE ELECTRIC HEATER COMPANY IS

DIMENSIONS ARE IN INCHES TOLERANCES: (UNLESS OTHERWISE SPECIFIED) FRACTIONAL ±1/4 ANGULAR: MACH ±½° BEND ±1° TWO PLACE DECIMAL ±0.01

THREE PLACE DECIMAL ±0.005

CHECKED

SIZE DWG. NO. JTX048-6T

48 kW @ 240 V, 3Ph

SCALE: 1:1 FSCM: 19857 SHEET 2 OF 2

REV

INSTALLATION PARAMETERS

240 V

48 kW

115.5 A

125 A

#1 AWG

8

VOLTS

POWER

AMP

BREAKER SIZE(MIN)

FEED WIRE SIZE(MIN)

CONDUIT SIZE(MIN)

WIRING DIAGRAM

3