

	ł	8	7	6	5 4 3
	ITEM NO.	QTY.	PART NO. / DWG. NO.	MATERIAL	DESCRIPTION
	1	1	D-1111	STAINLESS STEEL	BACK CASING ASSEMBLY
	2	1	D-1110	STAINLESS STEEL	FRONT COVER
	3	1	JTK6-FM	COPPER / BRASS	HEATER TUBE ASSEMBLY
	4				
D	5	6	N1375-9000T4	INCOLOY / BRASS	HEATING ELEMENT, 9000W @ 480V
	6	1	D-1114	ALUMINUM	TOP HEATER TUBE SUPPORT
	7	6	L93	VARIOUS	HI-LIMIT SWITCH, AUTO RESET (SET TO 200°F)
	8	1	TK FLOW BR	BRASS	FLOW METER, 0.2-8 GPM
	9				
	10	1	TK2250	VARIOUS	ELECTRONIC TEMPERATURE CONTROLLER
	11	1	TKD2000	VARIOUS	LED DISPLAY
	12	6	TG40E80	VARIOUS	TRIAC
	13	2	USP9509	VARIOUS	THERMISTOR
	14	AS REQ'D		COPPER	WIRE: POWER: #10 AWG, CONTROL: #18 AWG, THHN (90°C)
	15	1	KA-4C	COPPER	GROUND LUG
	16	1		POLYURETHANE	THERMISTOR INSULATION
	17				
	18	1	C25FNF360B	VARIOUS	MAGNETIC CONTACTOR, 208/240 VAC COIL, 75A RESISTIVE
С	19	1	B050-3299-3	VARIOUS	TRANSFORMER, 480/440 VAC TO 208 VAC
	20	3	PLUGBR 1/8	BRASS	DRAIN PLUG, 1/8" NPT
	21	5		RUBBER	INLET / OUTLET / DRAIN CASING GASKETS
	22	1	TANKLESS OVERLAY	LEXAN	DISPLAY OVERLAY
	23	1	COUPBELL 1/2" TO 3/4"	BRASS	INLET BELL COUPLING, 1/2" x 3/4"
	24	1	DIELECTRIC UNION	VARIOUS	DIELECTRIC UNION, 3/4" FNPT x 3/4" CTS
	25				
-	. 26	1		STAINLESS STEEL	INLET SCREEN (NOT SHOWN)
	27				
B	28				
	29	1		VARIOUS	LEAK DETECTION WIRE
	30	AS REQ'D		RUBBER	GASKET MATERIAL (NOT SHOWN)
	31	1	NIPPBR 3/4 X 1.5	BRASS	NIPPLE 3/4" x 1 1/2" LONG
	32	1	LGR-3	VARIOUS	CONTROL CIRCUIT FUSE, 3A
	33	1	LHR000	VARIOUS	FUSE HOLDER

INSTALLATION PARAMETERS						
480 V						
54 kW						
65.0 A						
70 A						
#4 AWG						
1"						
9						

**INSTALLATION NOTES:** 

1.

- TANKLESS WATER HEATERS ARE CONSIDERED A NON-CONTINUOUS LOAD. IF MULTIPLE FEED INSTALLATION IS USED, IT IS ACCEPTABLE TO INSTALL UP TO TWO 2. CONDUCTORS IN ONE LINE SIDE PORT. ADDITIONALLY, WHEN A POWER DISTRIBUTION BLOCK IS SUPPLIED, ADDITIONAL CONDUCTORS MAY BE INSTALLED IN AN OPEN LOAD SIDE PORT OF THE POWER DISTRIBUTION BLOCK. 3.
  - WIRING SIZING LISTED IS FOR 75°C THHN. 60°C OR 90°C WIRE MAY BE USED. REFER TO NEC TABLE 310.16 FOR SIZING.
- CONDUCTORS SHOULD BE SIZED TO MAINTAIN A VOLTAGE DROP OF LESS THAN 3% 4. UNDER LOAD.



1.

PROPRIETARY AND CONFIDENTIAL			
THE INFORMATION CONTAINED IN THIS	Dimensic		
DRAWING IS THE SOLE PROPERTY OF	Toleran		
THE ELECTRIC HEATER COMPANY. ANY	(Unless C		
REPRODUCTION IN PART OR AS A WHOLE	Fractioi		
WITHOUT THE WRITTEN PERMISSION OF	Angulai		
THE ELECTRIC HEATER COMPANY IS	Two Pla		
PROHIBITED.	Three Pla		

3

8

А

7

6

5

4

	I			2			1		1		
											D
GE 1. 2. 3. 4. 5. 6.	WA UN JTX AP HE FR(	Ati Ate IIt I ( Fl Pr Ati On	NG R P S UI OV OX ERS 1 0	CHAN RESSU L, CUL, V RATE IMATE ARE F TO 100	RE (N ANE E: 0.2 WEIC ULLY )%.	/AX.) D UL E GPN GHT IS MOE	ATED F Ph Lis MIN., 5 18 PC DULATI D/60 H;	ted. 8 gpt Dund: Ng	M MA	Χ.	С
											<b>←</b> B
	ZONE F	REV.			DES	CRIPTION REVISIOI	NS		DATE	APPROVED	
		D4	ATE	NAME	[.]			S	Stratford,	CT 06615	-
RAWN 11/17/10 PRD				hel		203) 378-	2659				
HECKED 11/22/10 SW		Г	The E	lectric	Heate	r Con	npany				
NG APPR. 11/22/10 PRD		Custor	mer:					A			
IFG APPR. 11/22/10 WEN III						D LIE איזי					
DIMENSIONS ARE IN INCHES TOLERANCES: (UNLESS OTHERWISE SPECIFIED) FRACTIONAL ±½ ANGULAR: MACH ±½° BEND ±1° TWO PLACE DECIMAL ±0.01 THREE PLACE DECIMAL ±0.005				v @ 480 DWG JTX(	ECTRIC V, 3Ph MO. D54-6T FSCM:	4		REV			
	I			2			ľ		1		-